



Food



Lodging



Pools



Wells



Septic



Humane



Radon

Chemical Use Requirements for Pools with Electronic Monitoring Devices

Pool Type	Minimum Chlorine	Combined Chlorine	Minimum Bromine	pH	Alkalinity
Whirlpool Exercise Pool Therapy Pool	3PPM	Less than 0.8 PPM	4 PPM	7.4-7.6	60-180 PPM
All other types of pools	1 PPM	Less than 0.6 PPM	3 PPM	7.4-7.6	60-180 PPM

- Cyanuric acid use in outdoor pools may not exceed 30 PPM
- ORP 650-900 mV
- Whirlpool temperature may not exceed 104°F
- Outdoor swimming pool temperature may not fall below 65°F

***Adjust temperature, alkalinity, and hardness to maintain a saturation index between -.3 and .3**

List of Required Documents to be Maintained Onsite

These files to be maintained onsite permanently.

- Pool Architectural Plans (if built after 7/1/2023)
- Copy of ATCP 76
- Pump manufacturer's pump performance curve
- Drain covers' spec sheets
- VGBA drain cover replacement log (provided by department)
- Instruction manual for pool's filter and other necessary equipment
- CDC's fecal incident response guidelines
- Death-injury-illness report (7 years after incident)
- Fecal-vomit-blood incident response report (2 years after incident)
- Daily chemical testing logs (provided by department kept for 2 years)
- Anti-entrapment device or system testing (2 years when applicable)
- Any lab bacteriological reports (2 years)